

<i>Year</i>	<i>Production (Rs. in Crores)</i>	<i>Sales (Rs. in Crores)</i>	<i>Employment (Lakh persons)</i>
1983-84	31.90	38.73	5.27
1984-85	40.55	49.55	6.25
1985-86	43.42	53.97	6.40
1986-87	57.10	68.04	6.65
1987-88	74.03	84.18	6.88

### **Tatkal Telephone Scheme**

8722. SHRI HUSSAIN DALWAI: Will the Minister of COMMUNICATIONS be pleased to state:

(a) whether telephone connections were to be provided in the city of Bombay under the Tatkal Scheme by mere asking on payment of Rs. 50,000/- ;

(b) if so, the number of telephone connections provided under the said scheme during 1988-89; and

(c) whether it is proposed to reduce the deposit money for this scheme in 1988-89?

THE MINISTER OF STATE IN THE MINISTRY OF COMMUNICATIONS (SHRI GIRIDHAR GOMANGO): (a) The telephone connections under the Tatkal Scheme are provided in the country including the city of Bombay on payment of Rs. 30,000/-, within two weeks of payment if feasible.

(b) 696 telephone connections were provided in Bombay under this scheme during 1988-89.

(c) No, Sir.

### **Noise pollution due to Thermal Power Stations in Delhi**

8723. SHRI HUSSAIN DALWAI: Will the Minister of ENERGY be pleased to state:

(a) whether there is great noise pollution on account of two Thermal Power Stations in Delhi;

(b) whether the level of noise pollution due to load shedding of these two power stations at night is more than during the day; and

(c) if so, the measures contemplated by Government to prevent this noise pollution in Delhi?

THE MINISTER OF STATE IN THE DEPARTMENT OF POWER IN THE MINISTRY OF ENERGY (SHRI KALP NATH RAI): (a) The measurements carried out by the Central Pollution Control Board indicate a noise level of 100-110 dB(A) at the Indraprastha Power Station which is marginally higher than the level of 90 dB(A), (8 hours average), as acceptable by the World Health Organisation. No measurements have been carried out at the Badarpur Thermal Power Station so far.

(b) During night time, the noise level is