

group of companies could, however be furnished, if required.

**Steps to Prevent Power crisis in Delhi during ASIAD '82**

4815. SHRI ZAINAL ABEDIN: Will the Minister of ENERGY be pleased to state:

(a) whether it is a fact that bigger power crisis may engulf Delhi during the Asiad '82';

(b) if so, the details thereof;

(c) whether Government are taking any steps so that the power crisis may be avoided;

(d) if so, details thereof; and

(e) if not, the reasons thereof?

THE MINISTER OF STATE IN THE MINISTRY OF ENERGY (SHRI VIKRAM MAHAJAN): (a) to (e). The power position in Delhi is much better as compared to earlier years. Normally the availability of power is more than its requirements. Further, the maximum power requirement of Delhi during Nov./December, 1982, when Asian Games are proposed to be held, is estimated as 650 MW, including power demand of about 50 MW for various Asian Games Complexes, various hotels, Palam Airport, Ring Railway, etc. In order to meet this demand and ensure adequate and uninterrupted power supply to various Asian Games complexes, new transmission lines and underground cables have been completed. Transformation capacities have also been augmented by adding new transformers or constructing new sub-station at the following locations:

(a) Mehrauli . . .	100 MVA
(b) Ridgevalley . . .	60 MVA
(c) Baird Road . . .	25 MVA
(d) Vidyut Bhavan . . .	40 MVA
(e) S.P. Marg . . .	25 MVA
(f) Tilak Marg . . .	12.5 MVA
(g) Lodi Road . . .	40 MVA
(h) Siri Fort . . .	23 MVA
(i) I. P. Stadium . . .	15 MVA

Diesel Generating sets are also being kept as standby at some of the Asian Games complexes for use in emergency. All efforts are being made to supply uninterrupted and reliable power supply during Asian Games.

The power requirements would be normally made from I.P. Station and BTPS. In the event of shortfall from these sources, power would be drawn from central generation projects and a contingency plan for meeting uninterrupted power supply to Delhi from Northern Region Grid have been drawn up.

Further, the maintenance and overhauling of the machines at I.P. and Badarpur Power Station has been so arranged that all the machines are available during the Asian Games.

**बार. एफ. ओ. के मूल्यों में वृद्धि**

4916. श्री नरसिंह शकबाना : क्या ~~उत्पादों की बढ़ती हुई कीमत~~, रसायन और उर्वरक मंत्री यह बताने की कृपा करेंगे कि :

(क) गत वर्ष बार. एफ. ओ. के मूल्यों में कितनी बार वृद्धि हुई और इस के क्या कारण हैं :

(ख) बार. एफ. ओ. के वर्तमान मूल्य क्या हैं और क्या सरकार का विचार इसके मूल्यों में और वृद्धि करने का है;

(ग) बार. एफ. ओ. के मूल्यों में कमी करने के लिए सरकार को कितनी मांगें प्राप्त हुईं और ये मांगें किन तोगों से प्राप्त हुई हैं ; और

(घ) किन किन तारीखों को इन मांगों पर विचार किया गया और उन पर निर्णय लिया गया ?

~~उत्पादों की बढ़ती हुई कीमत~~, रसायन और उर्वरक मंत्री (श्री पी. जिव शंकर) : (क) अन्य बातों के साथ-साथ आयातित अशोधित तेल तथा ~~उत्पादों की बढ़ती हुई कीमत~~ उत्पादों की बढ़ती हुई कीमत के परिणामस्वरूप तथा देशी अशोधित तेल के मूल्यों में संशोधन के कारण अतिरिक्त लागत के भार को पूरा करने के लिए 1981 में बार. एफ. ओ. (एल. एस. एच.