

(a) There is at present shortage in the available power of about 0.56 million units/day in Bihar (excluding DVC) and 3.3 million units/day in Uttar Pradesh power systems.

(b) For Bihar : Supply of good quality coal is being arranged for the thermal power stations in Bihar for reducing forced outages of thermal units. Repairs of the rotor for the second 50 MW unit at Pathratu being carried out by the Bharat Heavy Electricals Limited is being expedited. Main steam valve of one of the boilers for a 100 MW set at Pathratu is being air freighted. Construction of Joda-Chandil 220 KV inter-state line between Orissa and Bihar is being expedited.

For Uttar Pradesh : Power supply from Madhya Pradesh to Uttar Pradesh is being made to the extent possible. Commissioning of the 100 set at Obra thermal power station in Uttar Pradesh is being expedited.

(c) The total daily production of electricity in Bihar and Uttar Pradesh is respectively 5.56 million units (excluding DVC) and 21 million units.

**Introduction of an Express Service between Ranchi and Delhi**

311. KUMARI KAMLA KUMARI: Will the Minister of RAILWAYS be pleased to state :

(a) whether Government propose to introduce an Express Service between Ranchi and Delhi via Chopan, Chunar and Garhwa Road; and

(b) if so, the time by which it would be introduced ?

THE MINISTER OF RAILWAYS (SHRI T. A. PAD):

(a) No.

(b) Does not arise.

**Setting up of a Power Plant in Bihar**

312. KUMARI KAMLA KUMARI: Will the Minister of IRRIGATION AND POWER be pleased to state :

(a) whether a power plant was proposed to be set up in Palamau District in Bihar;

(b) whether it is proposed to be shifted elsewhere now; and

(c) if so, the reaction of Government in this regard ?

THE DEPUTY MINISTER IN THE MINISTRY OF IRRIGATION AND POWER (SHRI B. N. KUREEL):

(a) to (c). There is a proposal to instal a hydro power plant of 72 MW capacity under the Koel Karo Hydro Electric Project in Palamau District of Bihar. This project has now been proposed for implementation in the Fifth Plan. Being a hydro-electric project, it is not capable of being shifted elsewhere.

**सूखाग्रस्त क्षेत्रों में सिंचाई योजनायें**

313. श्री ईश्वर चौधरी :

श्री अण्णा साहूय्य मोटसिण्डे :

क्या सिंचाई और विद्युत मंत्री यह बताने की कृपा करेंगे कि :

(क) क्या सरकार का पांचवी योजना के अन्तर्गत सूखाग्रस्त क्षेत्रों में सिंचाई योजनायें की प्राथमिकता देने का विचार है ; और

(ख) यदि हाँ, तो तत्सम्बन्धी मुख्य बातें क्या हैं ?

सिंचाई और विद्युत मंत्रालयों में उपमंत्री (श्री बंजनाथ कुरील) : (क) और (ख) . पांचवी योजना के लिए प्रस्तावों को अभी तक अंतिम रूप नहीं दिया गया है। पांचवी योजना में नई स्कीमों को शामिल करने के प्रश्न पर विचार करते समय, उन स्कीमों को प्राथमिकता देने का विचार है जिनसे सुखाग्रस्त क्षेत्रों को लाभ पहुंचेगा।

बिजली की कमी संबंधी एक समिति  
की नियुक्ति

314. श्री ईश्वर चौधरी :  
श्री मार्तण्ड सिंह रीवा :

क्या सिंचाई और विद्युत मंत्री यह बताने की कृपा करेंगे कि :

(क) क्या सरकार ने देश में बिजली की भयंकर कमी के कारणों की जांच के लिए एक समिति नियुक्त की है और क्या इस समिति ने कोई रिपोर्ट सरकार को दी है ;

(ख) क्या बिजली सप्लाई की स्थिति दिन-प्रति-दिन खराब हो रही है ; और

(ग) इस स्थिति में कब तक सुधार हो जाने की आशा है ?

सिंचाई और विद्युत मंत्रालय में उप-मंत्री श्री बंजनाथ कुरील) : (क) विद्युत आपूर्ति स्थिति में तत्काल सुधार लाने के लिए युक्ति निकालने हेतु एक मन्त्रि-दल की स्थापना की गई है।

(ख) और (ग) . वर्तमान सूखा के दौरान 25 मिलियन यूनिट प्रतिदिन तक का अभाव है। यह आशा की जाती है कि एक वर्ष के उपरान्त उसमें पर्याप्त कमी हो जाएगी बशर्ते कि मानसून अच्छी तरह से आए तथा 1. 4 मिलियन कि. वा. को अतिरिक्त जनन क्षमता का लक्ष्य पूरा हो जाए।

बालाघाट तक छोटी लाइन को बड़ी  
लाइन में बदलना

315. श्री ईश्वर चौधरी :  
श्री गंगा चरण बीक्षित :

क्या रेल मंत्री यह बताने की कृपा करेंगे कि :

(क) क्या बालाघाट जिले (मध्य प्रदेश) में बड़ी लाइन के अभाव के कारण वहां से मैंगनीज को दूसरे भागों में ले जाने में बड़ी असुविधा होती है ;

(ख) क्या रेलवे विभाग का विचार मीटर लाइन को बड़ी लाइन में बदलने का है और यदि हां, तो कब तक; और

(ग) यदि नहीं, तो इसके क्या कारण हैं ?

रेल मंत्री (श्री टी० ए० पाई) : (क) इस क्षेत्र से मैंगनीज अयस्क की दुलाई में कोई भारी कठिनाई नहीं हो रही है।