

<i>Sl. No.</i>	<i>Exchanges Name</i>	<i>Capacity</i>
68.	Neeranahalli	25
69.	Sadashiwgad	160
70.	Salkani	25
71.	Sambrani	56
72.	Santegulli	56
73.	Siddapur	176
74.	Siddar	25
75.	Sirsi	1088
76.	Sugavi	56
77.	Swarnagadde	25
78.	Umachagi	25
79.	Yellapur	192

[*Translation*]

Fire in Sub-Station of DESU

7013. SHRIMATI SANTOSH
CHOWDHARY:
SHRI RAJVEER SINGH:

Will the Minister of POWER AND NON-CONVENTIONAL ENERGY SOURCES be pleased to state:

(a) whether fire had broken out in the power sub-station of newly constructed "Sansad Vihar" on outer ring Road in January, 1992;

(b) if so, the causes thereof; and

(c) the remedial steps taken by DESU to avoid recurrence of such incidents in future?

THE MINISTER OF STATE OF THE MINISTRY OF POWER AND NON-CONVENTIONAL ENERGY SOURCES (SHRI KALP NATH RAI): (a) to (c). According to DESU, the fire in the said sub-station was caused due to a fault in the underground cable feeding the Triveni Cooperative Group Housing Society during electrification work. The fault in the cable has already been rectified. DESU carries out regular maintenance of the transmission & distribution system to avoid such incidents.

Rural Electrification in Bihar, Uttar Pradesh and Orissa

7014. SHRI RAM LAKHAN SINGH
YADAV:
SHRI MOHAMMAD ALI
ASHRAF FATMI:
SHRI RAM TAHAL
CHOUHARY: