GOVERNMENT OF INDIA POWER LOK SABHA

UNSTARRED QUESTION NO:4536 ANSWERED ON:20.12.2012 DELAY IN ELECTRIFICATION WORK Biswal Shri Hemanand ;Ray Shri Rudramadhab

Will the Minister of POWER be pleased to state:

(a) whether the Government has taken note of the poor performance of the contractors engaged by the Central Public Sector Undertakings (CPSUs) which resulted in delay in completion of the electrification work under the Rajiv Gandhi Grameen Vidyutikaran Yojana (RGGVY) during the Eleventh Five Year Plan;

(b) if so, the State-wise details thereof and the action taken/proposed to be taken by the Government thereon;

(c) whether the lack of distribution transformers/low capacities of transformers provided under RGGVY in partially electrified villages is resulting in difficulties in providing connection to even below Poverty Line households in various States; and

(d) if so, the details thereof and the corrective measures being taken/proposed to be taken by the Government in this regard?

Answer

THE MINISTER OF STATE (INDEPENDENT CHARGE) OF THE MINISTRY OF POWER (SHRI JYOTIRADITYA M. SCINDIA)

(a) & (b) : Under Rajiv Gandhi Grameen Vidyutikaran Yojana (RGGVY), the projects are to be executed on turnkey basis by the Implementing Agencies who award the contracts to the contractors. The performance of Central Public Sector Undertakings (CPSUs) viz. Powergrid Corporation of India Limited (PGCIL), National Hydro-electric Power Corporation (NHPC), National Thermal Power Corporation (NTPC) and Damodar Valley Corporation (DVC) and the progress achieved during 11th Plan Period is as under:-

CPSUs 11th plan

Un/de-electrified villages BPL households Coverage Achievement (as Percentage Coverage Achievement (as Percen on 30.11.2012) with respect on 30.11.2012) -tage with to coverage respect to coverage

 PGCIL
 8535
 8246
 97%
 2441214
 2113562
 87 %

 NHPC
 5774
 5573
 97%
 1555540
 1350826
 87%

 NTPC
 11470
 11245
 98%
 2564147
 2236262
 87%

 DVC
 3598
 3244
 90%
 344149
 226183
 66%

The State-wise coverage and achievement under RGGVY during 11th Plan Period in respect of all the four CPSUs, is at Annex.

(c) & (d) : Under RGGVY, High Voltage Distribution System (HVDS) has been envisaged. Under HVDS, instead of one large capacity transformer, a number of small capacity transformers have been sanctioned to reduce the chances of power theft and overall Aggregate Technical and Commercial (AT&C) losses. Adequate transformation capacity as per RGGVY guidelines has been provided to cover the proposed number of Below Poverty Line (BPL) and Above Poverty Line (APL) families in the Detailed Project Reports (DPRs) submitted by Implementing Agencies.